

**Central Plumbing & Rooter
P.O Box 2533
Alameda, CA 94501
Lic#815962**

4-30-07

**2530 Shattuck
Berkeley Ca.**

Video inspection if sewer shows sewer line to be in poor condition sewer has roots and fractures to joints. Sewer lateral is in non compliance to point of sale ordinance and is in need of replacement.

We hereby submit specifications and estimate for:

Replacement of sewer lateral from building outlet up to curb by trenchless pipe burst means, Estimate to include parts, labor, permit and 10-yr warranty. Work to be inspected by City inspector prior to back fill work also to include:

**Cutting and removal of concrete and repaving (if needed) in area of excavation
Installation of 4" HDPE SDR 17 sewer pipe from house outlet to curb
House outlet cleanout with backflow valve installation of curb side cleanout
Backfill and soil compaction
Testing and inspection of sewer with City Inspector
Permits**

\$3,700.00

Estimate for 4" sewer only

**Thank you
Paul Croxton
510-521-1411**